



# Rockland County

Ed Day, Rockland County Executive

## DEPARTMENT OF PLANNING

Dr. Robert L. Yeager Health Center

50 Sanatorium Road, Building T

Pomona, New York 10970

Phone: (845) 364-3434 Fax: (845) 364-3435

**Douglas J. Schuetz**

*Acting Commissioner*

**Arlene R. Miller**

*Deputy Commissioner*

May 15, 2018

Grand View-on-Hudson Planning Board

204 Hudson Terrace

Piermont, NY 10968

**Tax Data:** 71.38-1-1

**Re: GENERAL MUNICIPAL LAW REVIEW:** Section 239 L and M, Section 239 N

**Map Date:** 1/25/2018

**Date Review Received:** 4/20/2018

**Item:** 67 RIVER ROAD (GV-29C)

Two-lot subdivision of 1.66 acres in the R-22 zoning district. Site plan for the two separate lots once the subdivision has been approved, and the required variances sought.

West side of River Road, approximately 1,570 feet south of I-87/287

### Reason for Referral:

River Road (CR 1), Town of Orangetown, US Route 9W

The County of Rockland Department of Planning has reviewed the above item. Acting under the terms of the above GML powers and those vested by the County of Rockland Charter, I, the Commissioner of Planning, hereby:

### ***\*Recommend the following modifications***

- 1 The comments and conditions in the April 25, 2018 letter from the Rockland County Highway Department must be met.
- 2 As indicated in the March 19, 2018 letter from the Rockland County Department of Health, an application must be made to them for review of the stormwater system, to ensure compliance with the County Mosquito Code.
- 3 As required by the Rockland County Stream Control Act, the subdivision plan must be reviewed and signed by the Chairman of the Rockland County Drainage Agency before the County Clerk can accept the plan to be filed.
- 4 A review must be completed by the New York State Department of Transportation, any comments or concerns addressed, and all required permits obtained.

## **67 RIVER ROAD (GV-29C)**

- 5 The Town of Orangetown is one of the reasons this proposal was referred to this department for review. The municipal boundary approximately 42 feet west of the site and at the edge of the Hudson River, approximately 140 feet to the east of the site. As required under Section 239nn of the State General Municipal Law, the Town of Orangetown must be given the opportunity to review the proposed subdivision and provide any concerns related to the project to the Village of Grand View-on-Hudson.
- 6 The existing in-ground pool is located in a relatively flat area and is proposed to be removed. Constructing the proposed new single-family residence in that general area will reduce the disturbance to areas of steep slope and the potential for soil erosion. The village should consider alternative locations for the proposed structure in order to minimize its environmental impact and the required variance.
- 7 Water is a scarce resource in Rockland County; thus proper planning and phasing of this project are critical to supplying the current and future residents of the Villages, Towns, and County with an adequate supply of water. A letter from the public water supplier, stamped and signed by a NYS licensed professional engineer, shall be issued to the municipality, certifying that there will be a sufficient water supply during peak demand periods and in a drought situation.
- 8 If any public water supply improvements are required, engineering plans and specifications for these improvements shall be reviewed by the Rockland County Department of Health prior to construction. In order to complete an application for approval of plans for public water supply improvements, the water supplier must supply an engineer's report pursuant to the "Recommended Standards for Water Works, 2003 Edition," that certifies their ability to serve the proposed project while meeting the criteria contained within the Recommended Standards for Water Works. These standards are adopted in their entirety in 10 NYCRR, Subpart 5-1, the New York State regulations governing public water systems. Further, both the application and supporting engineer's report must be signed and stamped by a NYS licensed professional engineer and shall be accompanied by a completed NYS Department of Health Form 348, which must be signed by the public water supplier.
- 9 Public sewer mains requiring extensions within a right-of-way or an easement shall be reviewed and approved by the Rockland County Department of Health prior to construction.
- 10 Prior to the start of construction or grading, all soil and erosion control measures must be in place for the site. These measures must meet the latest edition (November 2016) of the New York State Guidelines for Urban Erosion and Sediment Control.
- 11 There shall be no net increase in the peak rate of discharge from the site at all design points.
- 12 Pursuant to General Municipal Law (GML) Section 239-m and 239-n, if any of the conditions of this GML review are overridden by the board, then the local land use board must file a report with the County Commissioner of Planning of the final action taken. If the final action is contrary to the recommendation of the Commissioner, the local land use board must state the reasons for such action.
- 13 In addition, pursuant to Executive Order 01-2017 signed by County Executive Day on May 22, 2017, County departments are prohibited from issuing a County permit, license, or approval until the report is filed with the County Commissioner of Planning. The applicant must provide to any County agency which has jurisdiction of the project: 1) a copy of the Commissioner report approving the proposed action; or 2) a copy of the Commissioner of Planning recommendations to modify or disapprove the proposed action, and a certified copy of the land use board statement overriding the recommendations to modify or disapprove, and the stated reasons for the land use board's override.

**67 RIVER ROAD (GV-29C)**

*Adlene Miller*  
for  
Deputy ~~Acting~~ Commissioner of Planning  
Douglas J. Schuetz

cc: Mayor Larry Lynn, Grand View-on-Hudson  
Rockland County Department of Highways  
Rockland County Department of Health  
Rockland County Drainage Agency  
New York State Department of Transportation  
  
Jay A. Greenwell, PLS, LLC  
Town of Orangetown

*\*NYS General Municipal Law Section 239 requires a vote of a 'majority plus one' of your agency to act contrary to the above findings.*

*The review undertaken by the Rockland County Planning Department is pursuant to, and follows the mandates of Article 12-B of the New York General Municipal Law. Under Article 12-B the County of Rockland does not render opinions, nor does it make determinations, whether the item reviewed implicates the Religious Land Use and Institutionalized Persons Act. The Rockland County Planning Department defers to the municipality forwarding the item reviewed to render such opinions and make such determinations if appropriate under the circumstances.*

*In this respect, municipalities are advised that under the Religious Land Use and Institutionalized Persons Act, the preemptive force of any provision of the Act may be avoided (1) by changing a policy or practice that may result in a substantial burden on religious exercise, (2) by retaining a policy or practice and exempting the substantially burdened religious exercise, (3) by providing exemptions from a policy or practice for applications that substantially burden religious exercise, or (4) by any other means that eliminates the substantial burden.*

*Proponents of projects are advised to apply for variances, special permits or exceptions, hardship approval or other relief.*

*Pursuant to New York State General Municipal Law §239-m(6), the referring body shall file a report of final action it has taken with the Rockland County Department of Planning within thirty (30) days after final action. A referring body which acts contrary to a recommendation of modification or disapproval of a proposed action shall set forth the reasons for the contrary action in such report.*

