



## **REAGAN ROAD SUBDIVISION (NS-15B)**

meeting both the lot area and lot width requirements.

2 Lot 46, the 250-foot vegetated buffer, must be designated as a conservation easement or protected by deed restrictions to ensure that it is not developed in the future. The two road right-of-way's that extend north to this parcel are unnecessary if this lot is to serve as a buffer area. These ROW extensions shall be eliminated, as they serve no purpose. Elimination of these two right-of-way extensions will allow a reconfiguration of the lots resulting in better conformity.

3 Lot 29 is considerably larger than the other residential parcels. The western portion of the lot is within the 100 foot-wide Orange and Rockland easement and aligned with Allik Way. This raises the question of whether a future extension of Allik Way is planned to connect to Lot 46. An explanation must be provided.

4 The final disposition of Lot 8 must be clarified. Given the size of this parcel and its proximity to the federal wetlands, information must be provided about the development plans for this land area.

5 The drainage easement area on Lot 9 must be clearly defined. An arrow pointing to Pond B is not sufficient. It must also be clarified whether the entire parcel is being dedicated to the Village. Given the awkward lot configuration, large wetland area and the detention pond, Lot 9 is not a developable parcel.

6 As required by the Rockland County Stream Control Act, the subdivision plan must be reviewed and signed by the Chairman of the Rockland County Drainage Agency before the County Clerk can accept the plan to be filed.

7 The Towns of Clarkstown and Ramapo are two of the reasons this proposal was referred to this department for review. The Clarkstown municipal boundary is along the eastern property line of the site; the Ramapo municipal border is immediately north of the site. New York State General Municipal Law states that the purposes of Sections 239-l, 239-m and 239-n shall be to bring pertinent inter-community and countywide planning, zoning, site plan and subdivision considerations to the attention of neighboring municipalities and agencies having jurisdiction. Such review may include inter-community and county-wide considerations in respect to the compatibility of various land uses with one another; traffic generating characteristics of various land uses in relation to the effect of such traffic on other land uses and to the adequacy of existing and proposed thoroughfare facilities; and the protection of community character as regards predominant land uses, population density, and the relation between residential and nonresidential areas. In addition, Section 239-nn was enacted to encourage the coordination of land use development and regulation among adjacent municipalities, and as a result development occurs in a manner that is supportive of the goals and objectives of the general area.

In a letter dated February 27, 2017, the Town of Clarkstown Planning Board expressed concerns about this proposal. They considered it to be an overutilization of the property that could affect the health, safety and welfare of the residents. The issues of a strained water supply, an unnecessarily high demand on utilities, drainage, traffic congestion and inadequate buffers were also raised. The Village must address these concerns.

The Town of Ramapo must be also given the opportunity to review the proposal and its impact on community character, traffic, water quantity and quality, drainage, stormwater runoff and sanitary sewer service. The areas of countywide concern noted above that directly impact the Towns of Clarkstown and Ramapo must be considered and satisfactorily addressed, as well as any additional concerns about the proposal.

## **REAGAN ROAD SUBDIVISION (NS-15B)**

8 A review must be completed by the Palisades Interstate Park Commission and their comments or concerns addressed.

9 If there is any encroachment into the Federal wetlands, a review must be completed by the United States Army Corps of Engineers and all required permits obtained.

10 The applicant must comply with the conditions of the Rockland County Health Department's letter of February 17, 2017.

11 A review must be completed by the Rockland County Sewer District #1 and all required permits obtained.

12 An updated review of the January 13, 2017 site plan must be completed by the Rockland County Drainage Agency. In addition, the applicant must satisfactorily address the comments in the Drainage Agency's September 21, 2016 letter.

13 The project narrative must include details about the type of residential development proposed. This information is not provided on the layout plan, the bulk table or the application form. Section D.1.f. of the previously submitted Full Environmental Assessment Form (FEAF) indicates that the new residential units will be multi-family (four or more units) without specifying a total number. The number of units proposed in each residential building must be provided. This is especially critical in order to determine the required on-site parking, sewer capacity requirements, water supply needs and the appropriate location for trash receptacles/dumpster enclosures. The project narrative must also address the seven non-residential parcels. Additional information must be provided about the parking on Lot 1, the school sites on Lots 2 and 18, development plans for Lot 8, and the final disposition of Lots 9, 10 and 46.

14 The layout plan shows residential structures on 39 of the 46 lots. The project narrative indicates that multi-family dwellings are proposed on 41 lots, and one lot will be developed with townhouses. The total number of lots specified in the narrative equals 47. All application materials must be consistent. The total number of residential lots and structures must be clarified, as well as the number of lots to be used for other purposes.

15 The proposed residential buildings must comply with all requirements of the New York State Uniform Fire Prevention and Building Code.

16 A review must be completed by the Rockland County Office of Fire and Emergency Services, the Village of New Square Fire Inspector, or the Moleston Fire District to ensure that there is sufficient maneuverability on site for fire trucks, in the event an emergency arises.

17 As noted in their February 17, 2017 letter, all major subdivisions, i.e., those with three or more lots, must be reviewed and approved by the Rockland County Department of Health (RCDOH) prior to filing with the county clerk. RCDOH is mandated by New York State law to ensure that such subdivisions will have both an adequate and satisfactory water supply and adequate and satisfactory sewerage facilities.

18 Water is a scarce resource in Rockland County; thus proper planning and phasing of this project are critical to supplying the current and future residents of the Villages, Towns, and County with an adequate supply of water. If any public water supply improvements are required, engineering plans and specifications for these improvements shall be reviewed and approved by the Rockland County Department of Health prior to construction in order to ensure compliance with Article II (Drinking Water Supplies) of the Rockland County Sanitary Code and Part 5 of the New York State Sanitary Code.

**REAGAN ROAD SUBDIVISION (NS-15B)**

- 19 For installation of a sanitary sewer system, engineering plans and specifications shall be reviewed and approved by the Rockland County Department of Health prior to construction.
- 20 The bulk table does not specify the zoning district or use group for which the standards are listed. This information must be provided, as well as an explanation for the asterisks shown on the table.
- 21 Educational facilities are located on Lots 2 and 18. Both lots are included on the same bulk table as the residential properties. A separate bulk table must be provided for these two lots indicating the LDR bulk requirements for schools, as well as any variances that are required.
- 22 Five parking spaces are shown on Lot 1 with no structure proposed. An additional four spaces are shown on Lot 2 to the east of the school access drive. These nine parking spaces are accessed from Roosevelt Avenue. It is unclear which use will be served by these parking spaces. If Lot 1 is serving the parking needs of the school on Lot 2, the lots must be combined. If this parcel is not part of the school site, a parking easement must be provided over Lot 1. In addition, parking is generally an accessory use. It is not clear if it is permitted as the primary or sole use on a parcel. Clarification must be provided.
- 23 There shall be no net increase in the peak rate of discharge from the site at all design points.
- 24 Prior to the start of construction or grading, a soil and erosion control plan shall be developed and in place for the entire site that meets the latest edition of the New York State Guidelines for Urban Erosion and Sediment Control.
- 25 A stormwater pollution prevention plan (SWPPP) was not provided. The SWPPP, if required, shall conform to the current regulations, including the New York State Stormwater Management and Design Manual (January 2015) and local ordinances.
- 26 The eastern half of the driveway for Lot 45 does not meet the edge of the road pavement; vehicles will be unable to back out into the right-of-way. This must be realigned.
- 27 The layout plan does not include sidewalks, building entrances, stairways, decks, window wells or other building features making it difficult to determine if the proposed development will comply with all requirements of the New York State Uniform Fire Prevention and Building Code. These details must be shown on the map.
- 28 The height of the proposed retaining wall on Lots 8 and 9 must be provided.

  
\_\_\_\_\_  
Douglas J. Schuetz  
Acting Commissioner of Planning

cc: Mayor Israel Spitzer, New Square  
Palisades Interstate Park Commission  
United States Army Corps of Engineers  
Rockland County Drainage Agency  
Rockland County Department of Health  
Rockland County Sewer District #1  
New York State Department of State  
Rockland County Office of Fire and Emergency Services  
Moleston Fire District  
Brooker Engineering, PLLC

**REAGAN ROAD SUBDIVISION (NS-15B)**

Towns of Clarkstown and Ramapo

ZD Square Realty Corp.

*\*NYS General Municipal Law Section 239 requires a vote of a 'majority plus one' of your agency to act contrary to the above findings.*

*The review undertaken by the Rockland County Planning Department is pursuant to, and follows the mandates of Article 12-B of the New York General Municipal Law. Under Article 12-B the County of Rockland does not render opinions, nor does it make determinations, whether the item reviewed implicates the Religious Land Use and Institutionalized Persons Act. The Rockland County Planning Department defers to the municipality forwarding the item reviewed to render such opinions and make such determinations if appropriate under the circumstances.*

*In this respect, municipalities are advised that under the Religious Land Use and Institutionalized Persons Act, the preemptive force of any provision of the Act may be avoided (1) by changing a policy or practice that may result in a substantial burden on religious exercise, (2) by retaining a policy or practice and exempting the substantially burdened religious exercise, (3) by providing exemptions from a policy or practice for applications that substantially burden religious exercise, or (4) by any other means that eliminates the substantial burden.*

*Proponents of projects are advised to apply for variances, special permits or exceptions, hardship approval or other relief.*

*Pursuant to New York State General Municipal Law §239-m(6), the referring body shall file a report of final action it has taken with the Rockland County Department of Planning within thirty (30) days after final action. A referring body which acts contrary to a recommendation of modification or disapproval of a proposed action shall set forth the reasons for the contrary action in such report.*

