

**DEPARTMENT OF PLANNING**

Dr. Robert L. Yeager Health Center  
50 Sanatorium Road, Building T  
Pomona, New York 10970  
Phone: (845) 364-3434 Fax: (845) 364-3435

**Douglas J. Schuetz**  
*Acting Commissioner*

**Arlene Miller**  
*Deputy Commissioner*

March 21, 2016

Orangetown Planning Board  
21 Greenbush Road  
Orangeburg, NY 10962

**Tax Data:** 68.08-1-5

**Re: GENERAL MUNICIPAL LAW REVIEW:** Section 239 L and M

**Map Date:** 2/19/2016

**Date Review Received:** 2/22/2016

**Item:** *PFIZER, INC. - HAMILTON BIOS PROJECT - BLD. 222 & 222A (O-905LLLLLL)*

Site plan for a proposed one-story, 4,008 sq. ft. addition to an existing 528,123 sq. ft. building located in the LI zoning district on 22.9 acres, in a research complex. This portion of the building will house a freezer module and associated mechanical space. A new sidewalk is proposed on the southern portion of the building, connecting this building to the building to the south. New piping lines for fire water, storm drainage, and liquid nitrogen will be installed.

North side of NYS Route 304, west side of N. Middletown Road

**Reason for Referral:**

NYS Route 304, N. Middletown Road


The County of Rockland Department of Planning has reviewed the above item. Acting under the terms of the above GML powers and those vested by the County of Rockland Charter, I, the Commissioner of Planning, hereby:

***\*Recommend the following modifications***

- 1 A review must be completed by the County of Rockland Department of Highways and all required permits obtained.
- 2 A review shall be completed by the New York State Department of Transportation and any required permits obtained.
- 3 Prior to the start of construction or grading, a soil and erosion control plan shall be developed and in place for the entire site that meets the latest edition of the New York State Guidelines for Urban Erosion and Sediment Control.

**PFIZER, INC. - HAMILTON BIOS PROJECT - BLD. 222 & 222A (O-905LLLLLL)**

4 There shall be no net increase in the peak rate of discharge from the site at all design points.



---

Douglas J. Schuetz  
Acting Commissioner of Planning

cc: Supervisor Andrew Stewart, Orangetown  
Rockland County Department of Highways  
New York State Department of Transportation  
Stantec Consulting Services, Inc.

Donn McMullen

*\*NYS General Municipal Law Section 239 requires a vote of a 'majority plus one' of your agency to act contrary to the above findings.*

*The review undertaken by the Rockland County Planning Department is pursuant to, and follows the mandates of Article 12-B of the New York General Municipal Law. Under Article 12-B the County of Rockland does not render opinions, nor does it make determinations, whether the item reviewed implicates the Religious Land Use and Institutionalized Persons Act. The Rockland County Planning Department defers to the municipality forwarding the item reviewed to render such opinions and make such determinations if appropriate under the circumstances.*

*In this respect, municipalities are advised that under the Religious Land Use and Institutionalized Persons Act, the preemptive force of any provision of the Act may be avoided (1) by changing a policy or practice that may result in a substantial burden on religious exercise, (2) by retaining a policy or practice and exempting the substantially burdened religious exercise, (3) by providing exemptions from a policy or practice for applications that substantially burden religious exercise, or (4) by any other means that eliminates the substantial burden.*

*Proponents of projects are advised to apply for variances, special permits or exceptions, hardship approval or other relief.*

*Pursuant to New York State General Municipal Law §239-m(6), the referring body shall file a report of final action it has taken with the Rockland County Department of Planning within thirty (30) days after final action. A referring body which acts contrary to a recommendation of modification or disapproval of a proposed action shall set forth the reasons for the contrary action in such report.*