Rockland County

Ed Day, Rockland County Executive

DEPARTMENT OF PLANNING
Dr. Robert L. Yeager Health Center
50 Sanatorium Road, Building T
Pomona, New York 10970
Phone: (845) 364-3434 Fax: (845) 364-3435

Douglas J. Schuetz
Acting Commissioner

Arlene R. Miller
Deputy Commissioner

August 19, 2019

Orangetown Planning Board
21 Greenbush Road
Orangeburg, NY 10962

Tax Data: 68.14-2-50 68.14-2-49

Re: GENERAL MUNICIPAL LAW REVIEW: Section 239 N
Map Date: 6/26/2019 **Date Review Received:** 7/31/2019

Item: ***ALATSAS - DWA LLC SUBDIVISION (O-2383)***

Three-lot subdivision of two existing lots located on 1.17 acres in the R-15 zoning district. The existing single family dwelling on Lot 68.14-2-50 (eastern) will remain while the one on Lot 68.14-2-49 (western) will be demolished.

Southeast corner of Mercury Drive and Harding Street, approximately 105 feet west of Fillmore Street

Reason for Referral:

Old Pascack Road (CR 30)

The County of Rockland Department of Planning has reviewed the above item. Acting under the terms of the above GML powers and those vested by the County of Rockland Charter, I, the Commissioner of Planning, hereby:

Recommend the following modifications

1 A review must be completed by the County of Rockland Department of Highways and any concerns addessed and required permits obtained.

2 As required by the Rockland County Stream Control Act, the subdivision plan must be reviewed and signed by the Chairman of the Rockland County Drainage Agency before the County Clerk can accept the plan to be filed.

3 A review must be done by the Rockland County Department of Health to ensure compliance with Article XIX (Mosquito Control) of the Rockland County Sanitary Code.

4 Prior to the start of construction or grading, all soil and erosion control measures must be in place for the site. These measures must meet the latest edition (November 2016) of the New York State Standards for Urban Erosion and Sediment Control.

5 There shall be no net increase in the peak rate of discharge from the site at all design points.

ALATSAS - DWA LLC SUBDIVISION (O-2383)

6 A stormwater pollution prevention plan (SWPPP) was not provided. The SWPPP, if required, shall conform to the current regulations, including the New York State Stormwater Management and Design Manual (January 2015) and local ordinances.

Douglas J. Schuetz
Acting Commissioner of Planning

cc: Supervisor Chris Day, Orangetown
Rockland County Department of Health
Rockland County Department of Highways
Rockland County Drainage Agency

Jay A. Greenwell, PLS, LLC

**NYS General Municipal Law Section 239 requires a vote of a 'majority plus one' of your agency to act contrary to the above findings.*

The review undertaken by the Rockland County Planning Department is pursuant to, and follows the mandates of Article 12-B of the New York General Municipal Law. Under Article 12-B the County of Rockland does not render opinions, nor does it make determinations, whether the item reviewed implicates the Religious Land Use and Institutionalized Persons Act. The Rockland County Planning Department defers to the municipality forwarding the item reviewed to render such opinions and make such determinations if appropriate under the circumstances.

In this respect, municipalities are advised that under the Religious Land Use and Institutionalized Persons Act, the preemptive force of any provision of the Act may be avoided (1) by changing a policy or practice that may result in a substantial burden on religious exercise, (2) by retaining a policy or practice and exempting the substantially burdened religious exercise, (3) by providing exemptions from a policy or practice for applications that substantially burden religious exercise, or (4) by any other means that eliminates the substantial burden.

Proponents of projects are advised to apply for variances, special permits or exceptions, hardship approval or other relief.

Pursuant to New York State General Municipal Law §239-m(6), the referring body shall file a report of final action it has taken with the Rockland County Department of Planning within thirty (30) days after final action. A referring body which acts contrary to a recommendation of modification or disapproval of a proposed action shall set forth the reasons for the contrary action in such report.