

DEPARTMENT OF PLANNING

Dr. Robert L. Yeager Health Center
50 Sanatorium Road, Building T
Pomona, New York 10970
Phone: (845) 364-3434 Fax: (845) 364-3435

Douglas J. Schuetz
Acting Commissioner

Arlene R. Miller
Deputy Commissioner

November 27, 2019

Orangetown Planning Board
21 Greenbush Road
Orangeburg, NY 10962

Tax Data: 69.10-2-21 69.14-1-28

Re: GENERAL MUNICIPAL LAW REVIEW: Section 239 L and M

Map Date: 7/30/2019

Date Review Received: 11/7/2019

Item: *HENRY KAUFMANN CAMPGROUNDS: PEDESTRIAN BRIDGE (O-1061T)*

Site plan for a pedestrian bridge to cross the Nauraushaun Brook at an existing camp located on 105.914 acres in the R-80 zoning district. Approaches to the bridge will also be constructed.

West side of Sickletown Road, north side of Blauvelt Road/Sickletown Road, east end of S. Reld Drive

Reason for Referral:

Sickletown Road (CR 23), Nauraushaun Brook, federal wetlands

The County of Rockland Department of Planning has reviewed the above item. Acting under the terms of the above GML powers and those vested by the County of Rockland Charter, I, the Commissioner of Planning, hereby:

****Recommend the following modifications***

- 1 A review must be completed by the County of Rockland Drainage Agency and all required permits obtained.
- 2 A review must be completed by the County of Rockland Department of Highways, any concerns addressed, and all required permits obtained.
- 3 The comments in the June 5, 2019 letter from the Rockland County Department of Health must be met.
- 4 If there is any encroachment into the Federal wetlands, a review must be completed by the United States Army Corps of Engineers and all required permits obtained.
- 5 The floodplain Administrator for the Town of Orangetown shall certify that the proposed construction is in compliance with the floodplain regulations of the Town and the Federal Emergency Management Agency.
- 6 Prior to the start of construction or grading, all soil and erosion control measures must be in place for the site. These measures must meet the latest edition (November 2016) of the New York State Standards for Urban Erosion and Sediment Control.

HENRY KAUFMANN CAMPGROUNDS: PEDESTRIAN BRIDGE (O-1061T)

- 7 There shall be no net increase in the peak rate of discharge from the site at all design points.
- 8 The 145 contour line stops at the east abatement. The contour line must tie into the wall.
- 9 The application form indicates the property receives water service from United Water. The form must be corrected to Suez.



Douglas J. Schuetz
Acting Commissioner of Planning

cc: Supervisor Chris Day, Orangetown
Federal Emergency Management Agency
Rockland County Department of Health
Rockland County Department of Highways
Rockland County Drainage Agency
United States Army Corps of Engineers

Leonard Jackson Associates

Donald Brenner

**NYS General Municipal Law Section 239 requires a vote of a 'majority plus one' of your agency to act contrary to the above findings.*

The review undertaken by the Rockland County Planning Department is pursuant to, and follows the mandates of Article 12-B of the New York General Municipal Law. Under Article 12-B the County of Rockland does not render opinions, nor does it make determinations, whether the item reviewed implicates the Religious Land Use and Institutionalized Persons Act. The Rockland County Planning Department defers to the municipality forwarding the item reviewed to render such opinions and make such determinations if appropriate under the circumstances.

In this respect, municipalities are advised that under the Religious Land Use and Institutionalized Persons Act, the preemptive force of any provision of the Act may be avoided (1) by changing a policy or practice that may result in a substantial burden on religious exercise, (2) by retaining a policy or practice and exempting the substantially burdened religious exercise, (3) by providing exemptions from a policy or practice for applications that substantially burden religious exercise, or (4) by any other means that eliminates the substantial burden.

Proponents of projects are advised to apply for variances, special permits or exceptions, hardship approval or other relief.

Pursuant to New York State General Municipal Law §239-m(6), the referring body shall file a report of final action it has taken with the Rockland County Department of Planning within thirty (30) days after final action. A referring body which acts contrary to a recommendation of modification or disapproval of a proposed action shall set forth the reasons for the contrary action in such report.