



Rockland County

Ed Day, Rockland County Executive

DEPARTMENT OF PLANNING

Dr. Robert L. Yeager Health Center
50 Sanatorium Road, Building T
Pomona, New York 10970

Phone: (845) 364-3434 Fax: (845) 364-3435

Douglas J. Schuetz
Acting Commissioner

Arlene R. Miller
Deputy Commissioner

June 18, 2018

Ramapo Zoning Board of Appeals
237 Route 59
Suffern, NY 10901

Tax Data: 49.07-1-38

Re: GENERAL MUNICIPAL LAW REVIEW: Section 239 L and M

Map Date: 3/26/2018

Date Review Received: 4/17/2018

Item: *BNOS SCHOOL/261 ROUTE 306 (R-2510C)*

Variances for minimum lot area, side setback, total side setback, side yard, rear setback, maximum development coverage, floor area ratio, courtyard width, on-site parking and parking in the front and side yards, to allow the existing modular structures to be used as a permanent school building. The 1.2-acre site is in an R-40 zoning district.

West side of Route 306, approximately 225 feet north of Viola Road

Reason for Referral:

NYS Route 306, Village of New Hempstead, Viola Road (CR 74)

The County of Rockland Department of Planning has reviewed the above item. Acting under the terms of the above GML powers and those vested by the County of Rockland Charter, I, the Commissioner of Planning, hereby:

****Disapprove***

1 As noted previously, on July 29, 2015, this department issued comments on the site plan proposal for a permanent school at this location. The plans for the temporary structures currently in place were not submitted for our review. It is unclear when the modular buildings were installed, or whether their temporary status has expired. This must be clarified. Based on aerial photography flown in April of 2016, these structures have been in place for approximately two years. We question whether this permanent proposal is an attempt to circumvent the time limits in place at the time of installation, as well as the recently adopted local law prohibiting the use of temporary modular buildings for schools. Prior to considering the requested variances, the Town must undertake a review of the special permit and site plan applications now required, given the proposed change from temporary to permanent structures.

BNOS SCHOOL/261 ROUTE 306 (R-2510C)

2 While the lot is undersized, the June 3, 2015 site plan for the permanent school more closely complied with the R-40 bulk standards than the current proposal. In addition to the minimum lot area variance of 35 percent, the applicant is seeking a 175 percent increase over the maximum permitted development coverage, and a 37.5 percent variance for maximum allowable floor area ratio. The onsite parking is deficient by 22 percent. Several significant yard and setback variances are also required. The current layout plan results in a gross overutilization of the site as evidenced by the number and magnitude of the variances required. The overall building footprint must be reduced, and one or more modular buildings removed, to more closely conform to the applicable bulk requirements.

3 Permitting development that does not comply with the applicable bulk standards can set an undesirable land use precedent and result in the overutilization of individual sites. As noted above, the applicant is seeking several substantial variances for this proposal. The ability of the existing infrastructure to accommodate oversized schools on undersized parcels is a countywide concern and must be evaluated. This evaluation must consider whether local roads will become more congested and the sewer system, stormwater management systems and the public water supply will be overburdened. The Town must consider the cumulative and regional impacts of permitting such development. The building footprint must be reduced, and one or more modular structures removed, to more closely comply with the R-40 bulk standards.

The following comments address our additional concerns about this proposal.

4 Calculations must be provided for development coverage and floor area ratio. The bulk table on earlier versions of the site plan specified that the proposed development coverage and floor area ratio were .70 requiring variances of 250 and 75 percent respectively. It is unclear how the extent of these variances has decreased when the site plan features have not changed. Clarification must be provided.

5 As noted in our last review, the southern driveway and the access to the parking area have been modified. Vehicle circulation and turning movements are improved, as a result. However, seven parking spaces have been eliminated resulting in the need for a parking variance. The bus drop off area has been relocated. While it is closer to the building entrance, it coincides with the parking lot access. This raises concerns about student safety. The proposed use of traffic cones to block the parking lot access must be closely monitored by school personnel.

6 As noted above, a parking variance is now required for the school. This department is not in favor of granting parking variances for sites with frontage on a state highway. Insufficient onsite parking has the potential to negatively affect the safe and efficient flow of traffic along Route 306. Special events such as parent-teacher conferences and assemblies will require more than 25 parking spaces for a student body of 256. Off site parking arrangements must be in place for large gatherings at the school. A reduction in the building footprint will result in fewer required parking spaces for daily operation of the school.

7 A review must be completed by the New York State Department of Transportation, and all required permits obtained.

8 The Planning Consultant for the immediately adjacent Village of New Hempstead issued comments on this proposal in a letter dated April 25, 2018. Specific concerns include traffic and circulation, as well as site plan issues. The applicant must satisfactorily address these concerns in accordance with New York State General Municipal Law Sections 239-L, M and NN.

9 An updated review of the March 26, 2018 site plan must be completed by the Rockland County Highway Department, and any required permits obtained. In addition, the applicant must comply with the conditions of the Highway Department's April 20, 2018 letter.

BNOS SCHOOL/261 ROUTE 306 (R-2510C)

10 An updated review of the March 26, 2018 site plan must be completed by the Rockland County Health Department, and any required permits obtained. In addition, the applicant must comply with the conditions of the Health Department's December 1, 2017 letter.

11 An updated review of the March 26, 2018 site plan must be completed by the Rockland County Sewer District #1, and any required permits obtained. In addition, the applicant must comply with the conditions in the Sewer District's January 25, 2018 letter.

12 The NYS Department of State has determined that the Town is not administering or enforcing the State Uniform Fire Prevention and Building Code in accordance with minimum standards set forth in 19 NYCRR part 1203. Given the concerns about the Town's administration and enforcement of the State Uniform Fire Prevention and Building Code raised in the Executive Deputy Secretary of State's letter of July 15, 2016, the school building must be held to the requisite minimum standards and comply with all requirements of this code.

13 The Town of Ramapo Building, Planning & Zoning Department's August 9, 2017 denial letter includes fifteen comments from the Fire Inspector that must be satisfactorily addressed. In addition, any concerns raised by the Rockland County Office of Fire and Emergency Services or the Monsey Fire Department with regard to access or maneuverability must be considered.

14 The application materials submitted to this department for review specify only one parcel, Lot 49.07-1-38. The actual site plan includes the subject site and a portion of the parcel to the north, Lot 49.07-1-37. A connection between the two parcels is proposed. This connection is not adequately addressed in the project narrative. An explanation must be provided as to the access and circulation link between these two parcels, and how the school on Lot 49.07-1-37 relates to the subject school. In addition, a site plan that shows both lots must be submitted for our review. The bulk table must include what it proposed, and any additional variances that may be required, for both parcels.

15 As mentioned above, the northern driveway on Lot 49.07-1-37 is serving as the access for the school on Lot 49.07-1-38. A driveway easement is no longer shown on Lot 49.07-1-37 in favor of Lot 49.07-1-38. All required easements must be shown on the map.

16 While the proposed on-site circulation is indicated, it must also be demonstrated that emergency vehicles and fire trucks have sufficient maneuverability to navigate between the two parcels.

17 The July 28, 2017 project narrative revision indicated that the existing modular building has an 8,800 SF building footprint. One story modular buildings are depicted on the map. The bulk table now specifies that the provided floor area ratio (FAR) is .55, or 38 percent greater than allowed. A .55 FAR corresponds to a 28,708 SF building. The total floor area of the modular structures must be provided, as well as the FAR calculation.

18 A narrow macadam drive is shown along the northern property line, and to the north of the modular structures. It appears to serve as a pedestrian access leading to the individual modular buildings. A fire lane is proposed immediately south of the macadam drive. This is an unsafe arrangement due to the potential for traffic conflicts between pedestrians and emergency vehicles. The fire lane must be relocated.

19 A turnaround area must be provided at the southern end of the parking lot. As currently configured, it will be difficult for a vehicle parked in space 12 to exit this space, or for a garbage truck to maneuver.

20 Parked vehicles must not impede access to the garbage enclosure.

BNOS SCHOOL/261 ROUTE 306 (R-2510C)

21 All proposed walkways must be clearly delineated on the site plan demonstrating that they will not impact vehicle movement and parking maneuverability on the site. A walkway must be installed on the east side of the building and crosswalks provided from the building to the parking area. The current drawing now includes a "proposed walk" label over what appears to be a raised island at the northeast corner of the parking lot. Several signs are also located on this feature making it unlikely that a walkway is feasible. Clarification must be provided.

22 A landscaping plan must be submitted for our review so we can determine if the proposal conforms to the special permit standards outlines in Article XII, particularly Section 376-1216.A.(3), as it relates to perimeter, parking lot and building plantings required for schools.

23 Low evergreen landscaping must be provided in front of the parking spaces facing Route 306 to shield headlights from shining into oncoming vehicles traveling on the state highway.

24 A lighting plan shall be provided that shows fields of illumination. This plan must demonstrate that the intensity of the candle lumens is less than 0.1 at the property line.


25 A scale must be provided on the vicinity map.

26 The special permit required for this proposal is subject to a review by this department as mandated by the New York State General Municipal Law.

27 The site plan application required for this proposal is subject to a review by this department as mandated by the New York State General Municipal Law.

28 Pursuant to General Municipal Law (GML) Section 239-m and 239-n, if any of the conditions of this GML review are overridden by the board, then the local land use board must file a report with the County Commissioner of Planning of the final action taken. If the final action is contrary to the recommendation of the Commissioner, the local land use board must state the reasons for such action.

29 In addition, pursuant to Executive Order 01-2017 signed by County Executive Day on May 22, 2017, County departments are prohibited from issuing a County permit, license, or approval until the report is filed with the County Commissioner of Planning. The applicant must provide to any County agency which has jurisdiction of the project: 1) a copy of the Commissioner report approving the proposed action; or 2) a copy of the Commissioner of Planning recommendations to modify or disapprove the proposed action, and a certified copy of the land use board statement overriding the recommendations to modify or disapprove, and the stated reasons for the land use board's override.



Douglas J. Schuetz
Acting Commissioner of Planning

cc: Supervisor Michael B. Specht, Ramapo
New York State Department of Transportation
Rockland County Department of Highways
Rockland County Department of Health
Rockland County Drainage Agency
Rockland County Sewer District #1
New York State Department of State
Rockland County Office of Fire and Emergency Services
Monsey Fire District

Anthony R. Celentano P.L.S.
Village of New Hempstead

BNOS SCHOOL/261 ROUTE 306 (R-2510C)

David Goldfinger/Congregation Divrei Chaim

Mona Montal, Chief of Staff

Rockland County Planning Board Members

**NYS General Municipal Law Section 239 requires a vote of a 'majority plus one' of your agency to act contrary to the above findings.*

The review undertaken by the Rockland County Planning Department is pursuant to, and follows the mandates of Article 12-B of the New York General Municipal Law. Under Article 12-B the County of Rockland does not render opinions, nor does it make determinations, whether the item reviewed implicates the Religious Land Use and Institutionalized Persons Act. The Rockland County Planning Department defers to the municipality forwarding the item reviewed to render such opinions and make such determinations if appropriate under the circumstances.

In this respect, municipalities are advised that under the Religious Land Use and Institutionalized Persons Act, the preemptive force of any provision of the Act may be avoided (1) by changing a policy or practice that may result in a substantial burden on religious exercise, (2) by retaining a policy or practice and exempting the substantially burdened religious exercise, (3) by providing exemptions from a policy or practice for applications that substantially burden religious exercise, or (4) by any other means that eliminates the substantial burden.

Proponents of projects are advised to apply for variances, special permits or exceptions, hardship approval or other relief.

Pursuant to New York State General Municipal Law §239-m(6), the referring body shall file a report of final action it has taken with the Rockland County Department of Planning within thirty (30) days after final action. A referring body which acts contrary to a recommendation of modification or disapproval of a proposed action shall set forth the reasons for the contrary action in such report.

