



# Rockland County

Ed Day, Rockland County Executive

---

## DEPARTMENT OF PLANNING

Dr. Robert L. Yeager Health Center  
50 Sanatorium Road, Building T  
Pomona, New York 10970  
Phone: (845) 364-3434 Fax: (845) 364-3435

**Douglas J. Schuetz**  
*Acting Commissioner*

**Arlene R. Miller**  
*Deputy Commissioner*

March 12, 2019

Ramapo Planning Board  
237 Route 59  
Suffern, NY 10901

**Tax Data:** 32.07-1-1

**Re: GENERAL MUNICIPAL LAW REVIEW:** Section 239 L and M

**Map Date:** 12/17/2018

**Date Review Received:** 1/7/2019

**Item:** *ORANGE & ROCKLAND UTILITIES BATTERY STORAGE FACILITY (R-1990E)*

Site plan for an unmanned battery energy storage facility to be located contiguous to the existing Orange & Rockland substation. It will consist of six 40-foot battery energy storage system containers, and related equipment. The 28.64 parcel is in an RR-80 zoning district.

Encompassing both sides of Diltz Road at the terminus, 1,050 feet southwest of Mountain Road

**Reason for Referral:**

Mahwah River, Harriman State Park, Town of Haverstraw, State and Federal Wetlands

The County of Rockland Department of Planning has reviewed the above item. Acting under the terms of the above GML powers and those vested by the County of Rockland Charter, I, the Commissioner of Planning, hereby:


***\*Recommend the following modifications***

- 1 The applicant must comply with the conditions of the Rockland County Drainage Agency's letter of January 23, 2019.
- 2 A review must be completed by the New York State Department of Environmental Conservation, and all required permits obtained.
- 3 If there is any encroachment into the Federal wetlands, a review must be completed by the United States Army Corps of Engineers and all required permits obtained.
- 4 The designated floodplain administrator for the Town of Ramapo shall certify that the proposed construction is in compliance with the floodplain regulations of the Town and the Federal Emergency Management Agency.
- 5 A review must be completed by the Palisades Interstate Park Commission, and their comments or concerns addressed.

## **ORANGE & ROCKLAND UTILITIES BATTERY STORAGE FACILITY (R-1990E)**

- 6 The Town of Haverstraw is one of the reasons this proposal was referred to this department for review. The municipal boundary is approximately 400 feet north of the site. As required under Section 239nn of the State General Municipal Law, the Town of Haverstraw must be given the opportunity to review the proposed site plan and provide any concerns related to the project to the Town of Ramapo.
- 7 The applicant must comply with the condition of the Rockland County Health Department's letter of February 5, 2019.
- 8 The Rockland County Health Department's February 5, 2019 letter references a January 10, 2019 site plan. This department has not been provided with the January 10, 2019 maps. If the most recent revisions are substantial, the revised drawings must be submitted for our review.
- 9 The proposed battery energy storage facility must comply with all requirements of the New York State Uniform Fire Prevention and Building Code.
- 10 A review must be completed by the Rockland County Office of Fire and Emergency Services, the Town of Ramapo Fire Inspector, or the Moleston-Hillcrest Fire District to ensure that there is sufficient maneuverability on site for fire trucks, in the event an emergency arises.
- 11 Prior to the start of construction or grading, all soil and erosion control measures must be in place for the site. These measures must meet the latest edition (November 2016) of the New York State Guidelines for Urban Erosion and Sediment Control.
- 12 There shall be no net increase in the peak rate of discharge from the site at all design points.
- 13 A stormwater pollution prevention plan (SWPPP) was not provided. The SWPPP, if required, shall conform to the current regulations, including the New York State Stormwater Management and Design Manual (January 2015) and local ordinances.
- 14 The limits of disturbance must be clearly delineated in the field, prior to any grading or construction on site, to ensure that no encroachment occurs in the wetlands or State parklands.
- 15 A landscaping plan shall be provided which includes supplemental plantings along the property line to buffer the view of the battery storage facility from Harriman State Park.
- 16 A lighting plan shall be provided that shows fields of illumination. This plan must demonstrate that the intensity of the candle lumens is less than 0.1 at the property line.
- 17 The site plan shall contain map notes that list all appropriate information, including the district details.
- 18 The development coverage variance required for this proposal is subject to a review by this department as mandated under the New York State General Municipal Law.
- 19 Pursuant to General Municipal Law (GML) Section 239-m and 239-n, if any of the conditions of this GML review are overridden by the board, then the local land use board must file a report with the County Commissioner of Planning of the final action taken. If the final action is contrary to the recommendation of the Commissioner, the local land use board must state the reasons for such action.
- 20 In addition, pursuant to Executive Order 01-2017 signed by County Executive Day on May 22, 2017, County departments are prohibited from issuing a County permit, license, or approval until the report is filed with the County Commissioner of Planning. The applicant must provide to any County agency which has jurisdiction of the project: 1) a copy of the Commissioner report approving the proposed action; or 2) a copy of the Commissioner of Planning recommendations to modify or disapprove the proposed action, and a certified copy of the land use board statement overriding the recommendations to modify or disapprove, and the stated reasons for the land use board's override.

**ORANGE & ROCKLAND UTILITIES BATTERY STORAGE FACILITY (R-1990E)**

  
\_\_\_\_\_  
Douglas J. Schuetz  
Acting Commissioner of Planning

cc: Supervisor Michael B. Specht, Ramapo  
United States Army Corps of Engineers  
Rockland County Drainage Agency  
New York State Department of Environmental Conservation  
Palisades Interstate Park Commission  
Rockland County Department of Health  
Rockland County Sewer District #1  
New York State Department of State  
Rockland County Office of Fire and Emergency Services  
Moleston/Hillcrest Fire District

Maser Consulting P.A.  
Town of Haverstraw  
Young/Sommer LLC

KCE NY3 LLC

Mona Montal, Chief of Staff

*\*NYS General Municipal Law Section 239 requires a vote of a 'majority plus one' of your agency to act contrary to the above findings.*

*The review undertaken by the Rockland County Planning Department is pursuant to, and follows the mandates of Article 12-B of the New York General Municipal Law. Under Article 12-B the County of Rockland does not render opinions, nor does it make determinations, whether the item reviewed implicates the Religious Land Use and Institutionalized Persons Act. The Rockland County Planning Department defers to the municipality forwarding the item reviewed to render such opinions and make such determinations if appropriate under the circumstances.*

*In this respect, municipalities are advised that under the Religious Land Use and Institutionalized Persons Act, the preemptive force of any provision of the Act may be avoided (1) by changing a policy or practice that may result in a substantial burden on religious exercise, (2) by retaining a policy or practice and exempting the substantially burdened religious exercise, (3) by providing exemptions from a policy or practice for applications that substantially burden religious exercise, or (4) by any other means that eliminates the substantial burden.*

*Proponents of projects are advised to apply for variances, special permits or exceptions, hardship approval or other relief.*

*Pursuant to New York State General Municipal Law §239-m(6), the referring body shall file a report of final action it has taken with the Rockland County Department of Planning within thirty (30) days after final action. A referring body which acts contrary to a recommendation of modification or disapproval of a proposed action shall set forth the reasons for the contrary action in such report.*

