



# Rockland County

Ed Day, Rockland County Executive

## DEPARTMENT OF PLANNING

Dr. Robert L. Yeager Health Center  
50 Sanatorium Road, Building T  
Pomona, New York 10970

Phone: (845) 364-3434 Fax: (845) 364-3435

**Douglas J. Schuetz**  
*Acting Commissioner*

**Arlene R. Miller**  
*Deputy Commissioner*

December 14, 2017

Spring Valley Planning Board  
200 N. Main Street  
Spring Valley, NY 10977

**Tax Data:** 57.55-1-54

**Re: GENERAL MUNICIPAL LAW REVIEW:** Section 239 N

**Map Date:** 6/12/2017

**Date Review Received:** 11/29/2017

**Item:** *SHMYER BREUER - 3 JOHN STREET (SV-852)*

A subdivision application to create two lots on 0.296 acres in the R-2 zoning district. Two-family residences are proposed for each lot. Variances will be required for lot area, lot width, front yard, side yard, rear yard, total side yard, and street frontage.

The southwestern corner of John Street and East Funston Avenue.

**Reason for Referral:**

South Main Street (NYS Route 45)

The County of Rockland Department of Planning has reviewed the above item. Acting under the terms of the above GML powers and those vested by the County of Rockland Charter, I, the Commissioner of Planning, hereby:

***\*Disapprove***

With approximately 12,899 sq. ft., the existing parcel is only slightly larger than the minimum lot area of 10,000 sq. ft. for a two-family use in this zone. The 6,471 and 6,427 sq. ft. proposed lots are 35.3% and 35.7% smaller than the required minimum, respectively. In addition, this proposal requires significant variances for lot width, street frontage, front yard, side yard, total side yard, and rear yard. The County has concerns about not just the overdevelopment of this specific property, but for the precedent set by this development. Should neighboring property owners seek similar relief, it will negatively impact the community character and result in a higher residential density prescribed by the zoning regulations. The subdivision must be disapproved.

The following comments address our additional concerns about this project:

**SHMYER BREUER - 3 JOHN STREET (SV-852)**


- 1 Permitting development that does not comply with the applicable bulk standards can set an undesirable land use precedent and result in the overutilization of individual sites. The proposed lots are 35.3% and 35.7% smaller than the required minimum lot area. Side and total side yards are 33% smaller than required. Lot widths are 38.3% smaller than required. The rear yard of lot 2 is 50% deficient and its front yards are 20% and 8% smaller than required. The ability of the existing infrastructure to accommodate increased residential density on undersized parcels is a countywide concern and must be evaluated. This evaluation must consider whether local roads will become more congested and the sewer system, stormwater management systems and the public water supply will be overburdened. The Village must consider the cumulative and regional impacts of permitting such development. In addition, the Village must consider modifying this application to only permit single-family residences, which would mitigate these impacts and bring the parcels more in line with the Village's bulk requirements.
- 2 The bulk table indicates the required lot width for Lot 2 is 100 feet. Lot 2 is a corner lot. Village regulations state that a two-family residence on a corner lot must have a width of 105 feet. The bulk table must be corrected.
- 3 A review shall be completed by the New York State Department of Transportation and any required permits obtained.
- 4 Water is a scarce resource in Rockland County; thus proper planning and phasing of this project are critical to supplying the current and future residents of the Villages, Towns, and County with an adequate supply of water. A letter from the public water supplier, stamped and signed by a NYS licensed professional engineer, shall be issued to the municipality, certifying that there will be a sufficient water supply during peak demand periods and in a drought situation.
- 5 If any public water supply improvements are required, engineering plans and specifications for these improvements shall be reviewed by the Rockland County Department of Health prior to construction. In order to complete an application for approval of plans for public water supply improvements, the water supplier must supply an engineer's report pursuant to the "Recommended Standards for Water Works, 2003 Edition," that certifies their ability to serve the proposed project while meeting the criteria contained within the Recommended Standards for Water Works. These standards are adopted in their entirety in 10 NYCRR, Subpart 5-1, the New York State regulations governing public water systems. Further, both the application and supporting engineer's report must be signed and stamped by a NYS licensed professional engineer and shall be accompanied by a completed NYS Department of Health Form 348, which must be signed by the public water supplier.
- 6 Public sewer mains requiring extensions within a right-of-way or an easement shall be reviewed and approved by the Rockland County Department of Health prior to construction.
- 7 A review must be completed by the County of Rockland Sewer District #1 and any required permits obtained from them.
- 8 A review must be completed by the Rockland County Department of Health to ensure compliance with Article XIX (Mosquito Control) of the Rockland County Sanitary Code.
- 9 As required by the Rockland County Stream Control Act, the subdivision plan must be reviewed and signed by the Chairman of the Rockland County Drainage Agency before the County Clerk can accept the plan to be filed.
- 10 Prior to the start of construction or grading, a soil and erosion control plan shall be developed and in place for the entire site that meets the latest edition of the New York State Guidelines for Urban Erosion and Sediment Control.
- 11 There shall be no net increase in the peak rate of discharge from the site at all design points.

**SHMYER BREUER - 3 JOHN STREET (SV-852)**

12 We request the opportunity to review any variances which may be necessary to implement the proposed subdivision.

13 Pursuant to General Municipal Law (GML) Section 239-m and 239-n, if any of the conditions of this GML review are overridden by the board, then the local land use board must file a report with the County Commissioner of Planning of the final action taken. If the final action is contrary to the recommendation of the Commissioner, the local land use board must state the reasons for such action.

14 In addition, pursuant to Executive Order 01-2017 signed by County Executive Day on May 22, 2017, County departments are prohibited from issuing a County permit, license, or approval until the report is filed with the County Commissioner of Planning. The applicant must provide to any County agency which has jurisdiction of the project: 1) a copy of the Commissioner report approving the proposed action; or 2) a copy of the Commissioner of Planning recommendations to modify or disapprove the proposed action, and a certified copy of the land use board statement overriding the recommendations to modify or disapprove, and the stated reasons for the land use board's override.



Douglas J. Schuetz  
Acting Commissioner of Planning

cc: Mayor Alan Simon, Spring Valley  
New York State Department of Transportation  
Rockland County Department of Health  
Rockland County Drainage Agency  
Rockland County Sewer District #1

Anthony R. Celentano P.L.S.

Rockland County Planning Board Members

*\*NYS General Municipal Law Section 239 requires a vote of a 'majority plus one' of your agency to act contrary to the above findings.*

*The review undertaken by the Rockland County Planning Department is pursuant to, and follows the mandates of Article 12-B of the New York General Municipal Law. Under Article 12-B the County of Rockland does not render opinions, nor does it make determinations, whether the item reviewed implicates the Religious Land Use and Institutionalized Persons Act. The Rockland County Planning Department defers to the municipality forwarding the item reviewed to render such opinions and make such determinations if appropriate under the circumstances.*

*In this respect, municipalities are advised that under the Religious Land Use and Institutionalized Persons Act, the preemptive force of any provision of the Act may be avoided (1) by changing a policy or practice that may result in a substantial burden on religious exercise, (2) by retaining a policy or practice and exempting the substantially burdened religious exercise, (3) by providing exemptions from a policy or practice for applications that substantially burden religious exercise, or (4) by any other means that eliminates the substantial burden.*

*Proponents of projects are advised to apply for variances, special permits or exceptions, hardship approval or other relief.*

*Pursuant to New York State General Municipal Law §239-m(6), the referring body shall file a report of final action it has taken with the Rockland County Department of Planning within thirty (30) days after final action. A referring body which acts contrary to a recommendation of modification or disapproval of a proposed action shall set forth the reasons for the contrary action in such report.*

